



Oilfield Mechanical Services

NAMING CONVENTIONS

BRAND	EQUIP type	RATING	ENGINE type	LAMP type	CANOPY type	BASE config	FUEL TANK config	ORIGIN region	SOLAR type	MAST type	DESCRIPTION
MP											MP-Power
	BLANK										Generator
	A										Alternator
	L										Lighting tower
	LS										Lighting Tower (Solar)
	W										Welder
		XXXX									Generator - Standby Rating - kVA
		XXXX									Alternator - Standby Rating - kVA
		XXXX									Lighting equipment - klm (kilo-lumens)
		XXXX									Welding equipment - Amps
			BLANK								Not Applicable (for Alternators)
			C								Cummins
			D								Doosan
			L								Lombardini
			M								MTU
			P								Perkins
			R								Ruggerini
			V								Volvo
			Y								Yanmar
			Z								Deutz
				BLANK							Not applicable
				MH							Metal-halide
				LED							LED
					BLANK						Open Configuration
					S						Sound Attenuated Canopy
					SS						Super-sound Attenuated Canopy w/ noise attenuating baffles
						BLANK					Skid
						T					Trailer
						F					Forklift
							BLANK				4-12 hours at 75% of prime power rating
							-XR				approx 24 hours at 75% of prime power rating
							-XXR				+30 hours at 75% of prime power rating

								BLANK			New Zealand/Asia
								-E			Europe
									BLANK		High Sunlight
									EX		Medium Sunlight
									WG		Low Sunlight with Wind Generator
										BLANK	Manual Mast
										H	Hydraulic Mast